


**NMEA2000® 4-20mA PRESSURE ADAPTOR**

**Part Number: 4601**

**USER MANUAL**



**Revision 1.01**



<b>1 Introduction .....</b>	<b>2</b>
<b>1.1 Firmware revision.....</b>	<b>2</b>
<b>1.2 Product features.....</b>	<b>2</b>
<b>2 Installation.....</b>	<b>3</b>
<b>2.1 Unpacking the box.....</b>	<b>3</b>
<b>2.2 Mounting the unit.....</b>	<b>3</b>
<b>2.3 Connecting the NMEA2000® Interface.....</b>	<b>3</b>
<b>2.4 Connecting the 4-20mA sensor to the 4601 Adaptor.....</b>	<b>5</b>
<b>2.5 Configuration.....</b>	<b>5</b>
<b>2.5.1 Setting Device Instance.....</b>	<b>5</b>
<b>2.5.2 Setting Damping &amp; Pressure Source &amp;     Pressure Range.....</b>	<b>5</b>
<b>3 Maintenance.....</b>	<b>7</b>
<b>4 Technical specification.....</b>	<b>8</b>
<b>5 Technical support.....</b>	<b>10</b>
<b>6 Warranty.....</b>	<b>11</b>



# 1

## INTRODUCTION

The Oceanic Systems NMEA2000® 4601 4 - 20mA Pressure Adaptor is designed to monitor any 4 - 20mA pressure source including Atmospheric, Water, Steam, Compressed Air, Hydraulic, Oil & Fuel on the NMEA2000® network.

This unit is designed to operate in a protected marine environment such as an engine room. It is very important that it is installed and set up correctly according to this manual. Please read and follow the installation and setup instructions carefully to achieve the best results.

### 1.1 FIRMWARE REVISION

The information in this manual corresponds to firmware revision 1.00

### 1.2 PRODUCT FEATURES

The NMEA2000® 4601 4 - 20mA Pressure Adaptor has the following features:

- Convert 4 - 20mA pressure input to digital value with  $\pm 2\%$  full scale deflection
- Heartbeat blue LED confirming NMEA transmission.
- Faulty sensor/connection detection (under or over current)
- User selectable pressure range
- User selectable pressure source
- User selectable pressure damping
- IP67 protected
- NMEA2000® micro C interface plug
- Panel mounting

## 2

# INSTALLATION


## 2.1 UNPACKING THE BOX

You should find the following items in the 4601 shipping box:

- 1 x 4601 NMEA2000® 4-20mA Pressure Adaptor
- 1 x 4601 User Manual (This document)

## 2.2 MOUNTING THE UNIT


1. The unit should be mounted to a flat surface using 4 mounting screws.
2. The unit dimensions and mounting hole's locations are shown on the following drawing:



## 2.3 CONNECTING THE NMEA2000® CABLE

1. The unit is connected to the NMEA2000® network by the 5 way micro C socket on the front.
2. Carefully attach the network drop cable to this plug and hand tighten until it is fully seated.
3. Take care to match the orientation of the pip inside the socket to the recess inside the drop cable plug.
4. The other end of the drop cable should be connected to a suitable Tee connector on the NMEA2000® network backbone cable.

## 2.4 CONNECTING THE 4 - 20MA SENSOR TO THE 4601 ADAPTOR



The connections for the sensors are as follows:

Connector	Function
1	GND
2	4-20mA Sensor Input
3	24V Supply to Sensor

## 2.5 CONFIGURATION

The following items can be configured on the 4601 Adaptor.

### 2.5.1 SETTING DEVICE INSTANCE

It is possible to install 253 units of 4601 Pressure Adaptor on a NMEA2000® network so they need to each have a unique Device Instance Address. The Device Instance of each unit is set by turning the small rotary switch1 + switch2 with a small screw driver. The device instance is counted from (switch1 value \* 16) + switch2 value. Valid Device Instances range from “0x00” through to “0xFD”.

### 2.5.2 SETTING DAMPING & PRESSURE SOURCE & PRESSURE RANGE


To change the “damping” and “pressure source” settings, hold your magnet on the correct part of the product label as indicated on the label. When the magnet is close enough to the product,

the red LED will start to flash quickly. After 2 seconds the LED will flash once per second. At this point, turning the rotary switch will change the Damping and Pressure Source settings. See the table below for positionings. When the rotary switch is in the desired position, hold the magnet in the same place for a further 2 seconds until the red LED lights for 2.5 seconds, these settings are now saved.

Changing the “pressure range” setting is similar; hold the magnet in against the product, this time for 7 seconds until the red LED flashes twice per second. Set the Pressure Range with the rotary switch as per the table below. Then confirm the setting as before, by holding the magnet against the product or 2 seconds.

Once the settings have been successfully saved, remember to change the rotary switch back to reflect the device instance on the NMEA network.

**Fig 1**



Switch Values		
Switch Position	Pressure Source SW1	Damping (seconds) SW2
0	Atmospheric	Off
1	Water	1
2	Steam	2
3	Compressed Air	3
4	Hydraulic	4
5	Filter	5
6	Altimeter Setting	6



7	Oil	7
8	Fuel	8
9	Custom #130	9
A	Custom #131	10
B	Custom #132	15
C	Custom #133	20
D	Custom #134	25
E	Custom #135	Not Used
F	Custom #136	Not Used

<b>Switch Values</b>		
<b>Switch Position</b>	<b>Pressure Range SW1</b>	<b>SW2</b>
0	0 - 3 PSI	Not Used
1	0 - 5 PSI	Not Used
2	0 - 10 PSI	Not Used
3	0 - 50 PSI	Not Used
4	0 -100 PSI	Not Used
5	0 - 300 PSI	Not Used
6	0 - 500 PSI	Not Used
7	0 -1000 PSI	Not Used
8	0 - 3000 PSI	Not Used
9	0 - 5000 PSI	Not Used
A	Not Used	Not Used
B	Not Used	Not Used
C	Not Used	Not Used
D	Not Used	Not Used
E	Not Used	Not Used
F	0 - 1 BAR Vacuum	Not Used

- Clean the unit with a soft cloth.
- Do not use chemical cleaners as they may remove paint or markings or may corrode the enclosure or seals.
- Ensure that the unit is mounted securely and cannot be moved relative to the mounting surface. If the unit is loose, tighten the mounting screws.
- Check the security of the cables connected to the NMEA2000® connector, tighten if necessary.
- Check the security of the Crimp receptacle to the 4601 Spade Terminals

As Oceanic Systems is constantly improving their products, specifications are subject to change without notice. Oceanic Systems' products are designed to be accurate and reliable however they should only be used as aids to navigation and not as a replacement for traditional navigation aids and techniques.

### Design Standard

Parameters	Comment
NMEA2000®	Level B

### NMEA2000® Parameter Group Numbers (PGNs)

Parameters	PGN No.	PGN Name
Monitor	PGN130314	Actual pressure
Protocol	PGN126464	Tx/Rx PGN List
	PGN126996	Product information
	PGN059392	ISO Acknowledge
	PGN059904	ISO Request
	PGN060928	ISO Address Claim
	PGN126208	Command/Request Group

## Electrical and Mechanical

Parameters	Value	Comment
Operating Voltage	12 to 24 VDC	
Power Consumption	65mA	Average Operating
Load Equivalence Number	2	LEN
Reverse Battery Protection	Yes	Indefinitely
Load Dump Protection	Yes	SAE J1113
Size	mm	98 x 58 x 17
Weight	gr	140

## Environmental

Parameter	Value
IEC 60954 Classification	Protected
Degree of Protection	IP40
Operating Temperature	-20°C to 55°C
Storage Temperature	-40°C to 70°C
Relative Humidity	93%RH @40° per IEC60945-8.2
Vibration	2-13.2Hz @ ±1mm, 13.2-100Hz @ 7m/s <sup>2</sup> per IEC 60945-8.7
Electromagnetic Emission	Conducted and Radiated Emission per IEC 60945-9
Electromagnetic Immunity	Conducted, Radiated, Supply, and ESD per IEC 60945-10
Safety Precautions	Dangerous Voltage, Electromagnetic Radio Frequency per IEC 60945-12

If you require technical support for any Oceanic Systems products you can reach us using any of the following:-

- Tel: +44(0)1425 610022
- Fax: +44(0)1425 614794
- Email: [support@osukl.com](mailto:support@osukl.com)
- Web: [www.osukl.com](http://www.osukl.com)
- Post: Oceanic Systems Ltd  
Unit 10-11 Milton Business Centre  
Wick Drive, New Milton, Hampshire BH25 6RH

Oceanic Systems (UK) Ltd  
Unit 10-11 Milton Business Centre, Wick Drive,  
New Milton, Hampshire, BH25 6RH, United Kingdom

Tel: +44(0)1425 610022      Fax: +44(0)1425 614794  
Email: [sales@osukl.com](mailto:sales@osukl.com)      Web: [www.osukl.com](http://www.osukl.com)

Copyright © 2016 Oceanic Systems (UK) Ltd. All rights reserved. Our policy is one of continuous product improvement so product specifications are subject to change without notice. Oceanic Systems products are designed to be accurate and reliable. However, they should be used only as aids to vessel monitoring, and not as a replacement for traditional navigation and vessel monitoring techniques. NMEA2000® is a registered trademark of the National Marine Electronics Association.

Oceanic Systems warrants this product to be free from defects in materials and workmanship for one year from the date of original purchase. If within the applicable period any such products shall be proved to Oceanic Systems satisfaction to fail to meet the above-limited warranty, such products shall be repaired or replaced at Oceanic Systems option. Purchaser's exclusive remedy and Oceanic Systems sole obligation hereunder, provided product is returned pursuant to the return requirements below, shall be limited to the repair or replacement, at Oceanic Systems option, of any product not meeting the above limited warranty and which is returned to Oceanic Systems; or if Oceanic Systems is unable to deliver a replacement that is free from defects in materials or workmanship, Purchaser's payment for such product will be refunded. Oceanic Systems assumes no liability whatsoever for expenses of removing any defective product or part, or for installing the repaired product or part or a replacement therefore or for any loss or damage to equipment in connection with which Oceanic Systems products or parts shall be used. The foregoing warranties shall not apply with respect to products subjected to negligence, misuse, misapplication, accident, damage by circumstances beyond Oceanic Systems control, to improper installation, operation, maintenance, or storage, or to other than normal use or service.

**THE FOREGOING WARRANTIES ARE EXPRESSLY IN LIEU OF AND EXCLUDES ALL OTHER EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND OF FITNESS FOR A PARTICULAR PURPOSE.**

Statements made by any person, including representatives of Oceanic Systems, which are inconsistent or in conflict with the terms of this Limited Warranty, shall not be binding upon Oceanic Systems unless reduced to writing and approved by an officer of Oceanic Systems.

**IN NO CASE WILL OCEANIC SYSTEMS BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES, DAMAGES FOR LOSS OF USE, LOSS OF ANTICIPATED PROFITS OR SAVINGS, OR ANY OTHER LOSS INCURRED BECAUSE OF INTERRUPTION OF SERVICE. IN NO EVENT SHALL OCEANIC SYSTEMS AGGREGATE LIABILITY EXCEED THE PURCHASE PRICE OF THE PRODUCT(S) INVOLVED. OCEANIC SYSTEMS SHALL NOT BE SUBJECT TO ANY OTHER OBLIGATIONS OR LIABILITIES, WHETHER ARISING OUT OF BREACH OF CONTRACT OR WARRANTY, TORT (INCLUDING NEGLIGENCE), OR OTHER THEORIES OF LAW WITH RESPECT TO PRODUCTS SOLD OR SERVICES RENDERED BY OCEANIC SYSTEMS, OR ANY UNDERTAKINGS, ACTS OR OMISSIONS RELATING THERETO.**

Oceanic Systems does not warrant that the functions contained in any software programs or products will meet purchaser's requirements or that the operation of the software programs or products will be uninterrupted or error free. Purchaser assumes responsibility for the selection of the software programs or products to achieve the intended results, and for the installation, use and results obtained from said programs or products. No specifications, samples, descriptions, or illustrations provided by Oceanic Systems to Purchaser, whether directly, in trade literature, brochures or other documentation shall be construed as warranties of any kind, and any failure to conform to such specifications, samples, descriptions, or illustrations shall not constitute any breach of Oceanic Systems limited warranty.


### WARRANTY RETURN PROCEDURE

To apply for warranty claims, contact Oceanic Systems or one of its dealers to describe the problem and determine the appropriate course of action. If a return is necessary, place the product in its original packaging together with proof of purchase and send to an Authorized Oceanic Systems Service Location. You are responsible for all shipping and insurance charges. Oceanic Systems will return the replaced or repaired product with all shipping and handling prepaid except for requests requiring expedited shipping (i.e. overnight shipments). Failure to follow this warranty return procedure could result in the product's warranty becoming null and void.

Oceanic Systems reserves the right to modify or replace, at its sole discretion, without prior notification, the warranty listed above.

# OCEANIC SYSTEMS PRODUCT MAP

## NMEA2000® VESSEL MONITORING AND CONTROL SYSTEMS



Up to 16 of each type of device can be installed on a single network